



**Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road SE, Tumwater WA 98501**

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Name of Sampler: Connor Osterlund
Date Collected: 10/11/2018
School Name: Jefferson Elementary School
School Code: 3203
School District Name: Pullman
Address: 1150 NW Bryant St, Pullman WA 99163
County: Whitman
Number of Samples Collected: 56
School Point of Contact: Joseph Thornton
Title of POC: Director of Operations
Email of POC: Jthornton@psd267.wednet.edu
POC Phone Number: 5093345586
Date sent to State Lab: 10/11/2018
Date Received by Lab:
Shipment Tracking Number:

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	12996	First Draw	Bubbler	Outside gym	<1	10/17/2018	
2.	12997	First Draw	Tap	Kitchen	8	10/17/2018	Ran before sampling
3.	12998	First Draw	Tap	Kitchen	<1	10/17/2018	Ran before sampling left side
4.	12999	First Draw	Bubbler	Outside resource 2	<1	10/17/2018	Left
5.	13000	First Draw	Bubbler	Outside resource 2	<1	10/17/2018	
6.	13001	First Draw	Tap	Room 201	2	10/17/2018	
7.	13002	First Draw	Bubbler	Room 201	<1	10/17/2018	
8.	13003	First Draw	Tap	Room 202	8	10/17/2018	
9.	13004	First Draw	Tap	Room 202	1	10/17/2018	
10.	13005	First Draw	Tap	Room 203	2	10/17/2018	
11.	13006	First Draw	Bubbler	Room 203	1	10/17/2018	
12.	13007	First Draw	Tap	Room 204	2	10/17/2018	
13.	13008	First Draw	Bubbler	Room 204	1	10/17/2018	
14.	13009	First Draw	Tap	Room 205	2	10/17/2018	
15.	13010	First Draw	Bubbler	Room 205	<1	10/17/2018	
16.	13011	First Draw	Tap	Room 206	1	10/17/2018	
17.	13012	First Draw	Tap	Room 206	<1	10/17/2018	
18.	13013	First Draw	Tap	Room 500	3	10/17/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
19.	13014	First Draw	Bubbler	Room 500	1	10/17/2018	
20.	13015	First Draw	Tap	Room 505	<1	10/17/2018	
21.	13016	First Draw	Bubbler	Room 505	2	10/17/2018	
22.	13017	First Draw	Tap	room 506	2	10/17/2018	
23.	13018	First Draw	Bubbler	Outside north east wing	<1	10/17/2018	Left
24.	13019	First Draw	Bubbler	Outside north east wing	<1	10/17/2018	Right
25.	13020	First Draw	Bubbler	Room 601	<1	10/17/2018	
26.	13021	First Draw	Tap	Room 601	9	10/17/2018	
27.	13022	First Draw	Bubbler	Room 602	<1	10/17/2018	
28.	13023	First Draw	Tap	Room 602	2	10/17/2018	
29.	13024	First Draw	Bubbler	Room 603	1	10/17/2018	
30.	13025	First Draw	Bubbler	Room 603	3	10/17/2018	
31.	13026	First Draw	Bubbler	room 615	<1	10/17/2018	
32.	13027	First Draw	Tap	room 615	<1	10/17/2018	
33.	13028	First Draw	Bubbler	Room 613	<1	10/17/2018	
34.	13029	First Draw	Tap	Room 613	1	10/17/2018	
35.	13030	First Draw	Bubbler	room 604	<1	10/17/2018	
36.	13031	First Draw	Tap	Room 604	1	10/17/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
37.	13032	First Draw	Bubbler	Room 605	2	10/17/2018	
38.	13033	First Draw	Tap	Room 605	1	10/17/2018	
39.	13034	First Draw	bubbler	Room 606	<1	10/17/2018	
40.	13035	First Draw	Tap	Room 606	3	10/17/2018	
41.	13036	First Draw	Bubbler	Room 701	<1	10/17/2018	
42.	13037	First Draw	Tap	room 701	<1	10/17/2018	
43.	13038	First Draw	Bubbler	room 702	2	10/17/2018	
44.	13039	First Draw	Tap	Room 702	1	10/17/2018	
45.	13040	First Draw	Bubbler	Room 703	<1	10/17/2018	
46.	13041	First Draw	Tap	room 703	2	10/17/2018	
47.	13042	First Draw	Bubbler	Room 713	<1	10/17/2018	
48.	13043	First Draw	Tap	Room 713	<1	10/17/2018	
49.	13044	First Draw	Bubbler	Room 715	<1	10/17/2018	
50.	13045	First Draw	Tap	room 715	<1	10/17/2018	
51.	13046	First Draw	Bubbler	room 704	<1	10/17/2018	
52.	13047	First Draw	Tap	Room 704	<1	10/17/2018	
53.	13048	First Draw	Bubbler	room 705	<1	10/17/2018	
54.	13049	First Draw	Tap	room 705	1	10/17/2018	
55.	Room 13050	First Draw	Tap	room 706	2	10/17/2018	Bubbler no pressure

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
56.	13051	First Draw	Blank	Blank	<1	10/17/2018	