



**Office of Environmental Public Health Sciences  
Washington State Department of Health  
243 Israel Road SE, Tumwater WA 98501**

**Lead Sample Collection Information**

**DISCLAIMER:** Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

**Name of Sampler:** Connor Osterlund  
**Date Collected:** 10/17/2018  
**School Name:** Lincoln Middle School  
**School Code:** 3419  
**School District Name:** Pullman  
**Address:** 315 SE Crestview, Pullman WA 99163  
**County:** Whitman  
**Number of Samples Collected:** 25  
**School Point of Contact:** Joseph Thornton  
**Title of POC:** Director of operations  
**Email of POC:** Jthornton@psd267.wednet.edu  
**POC Phone Number:** 5093345586  
**Date sent to State Lab:** 10/17/2018  
**Date Received by Lab:**  
**Shipment Tracking Number:**

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	13146	First Draw	Tap	Kitchen	TB		
2.	13147	First Draw	Tap	Nurses station	5	10/25/2018	
3.	13149	First Draw	Tap	Room 202	3	10/25/2018	
4.	13150	First Draw	Bubbler	Room 202	3	10/25/2018	
5.	13151	First Draw	Tap	Room 203	9	10/25/2018	Bubbler no pressure
6.	13152	First Draw	Bubbler	Room 204	2	10/25/2018	
7.	13153	First Draw	Tap	Room 204	14	10/25/2018	
8.	13154	First Draw	Bubbler	Room 205	3	10/25/2018	
9.	13155	First Draw	Tap	Room 205	18	10/25/2018	
10.	13156	First Draw	Bubbler	Room 206	4	10/25/2018	
11.	13157	First Draw	Tap	Room 206	6	10/25/2018	
12.	13158	First Draw	Bubbler	Outside concession	<1	10/25/2018	Left
13.	13159	First Draw	Bubbler	Outside concession	<1	10/25/2018	Right
14.	13160	First Draw	Bubbler	Room 209	3	10/25/2018	
15.	13161	First Draw	Tap	Room 209	5	10/25/2018	
16.	13162	First Draw	Bubbler	Room 210	1	10/25/2018	
17.	13163	First Draw		Room 210	4	10/25/2018	
18.	13164	First Draw	Bubbler	Outside room 407	<1	10/25/2018	Left
19.	13165	First Draw	Bubbler	Outside room 407	<1	10/25/2018	Right

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
20.	13166	First Draw	Bubbler	Room 806	3	10/25/2018	
21.	13167	First Draw	Tap	Room 807	2	10/25/2018	
22.	13168	First Draw	Bubbler	Cafeteria	<1	10/25/2018	Left
23.	13169	First Draw	Bubbler	Cafeteria	<1	10/25/2018	Right
24.	13170	First Draw	Bottle Filler	Cafeteria	<1	10/25/2018	
25.	13171	First Draw	Blank	Blank	<1	10/25/2018	